



February 14, 2025

GABRIELE BENSON  
PINWOOD SPRINGS WD - PWSID CO0135610  
183 CREE CT  
LYONS CO 80540

### RESCIND OF TIER 1 BOTTLE WATER ADVISORY

Dear GABRIELE BENSON:

The Colorado Department of Public Health and Environment-Water Quality Control Division (the “Department”) issued a “Bottle Water Advisory” for the PINWOOD SPRINGS WD (the “Supplier”) on January 30, 2025 due to the presence of manganese above the EPA’s short-term Health Advisory Levels of 0.3 mg/L for infants under six-months of age.

Since the “Bottle Water Advisory” was issued, the Department has received the following information from the Supplier:

- The Supplier flushed the system and took two sets of manganese samples at five locations.
- The Supplier provided a description of the situation and flushing.
- Confirmation that all samples taken on February 11, 2025 were below the 0.3 mg/L Health Advisory Level for infants.

Based upon the actions taken by the supplier, the “Bottle Water Advisory” is hereby rescinded. Effective date of this action is **February 14, 2025**. The affected customers should be notified of the lifting of the “Bottle Water Advisory.” Public notice of the lifting of the “Bottle Water Advisory” should include contact information for the water system and should be provided in a similar manner to which the initial advisory was issued. A template can be created at [wqcdcompliance.com/pn](http://wqcdcompliance.com/pn) under “Problem Corrected”.

Please note, rescindment of the “Bottle Water Advisory” does not constitute compliance with public notification requirements. If not already completed, the Supplier must submit the certificate of delivery and copy of the original public notice to fulfill the regulatory public notification requirements for the “Bottle Water Advisory”.

If you have any further questions, please contact me at 303-692-3318 or via email at [bryan.pilson@state.co.us](mailto:bryan.pilson@state.co.us).

Sincerely,

Bryan Pilson

Technical, Regulatory Implementation, and Coordination Unit Manager  
Water Quality Control Division  
Colorado Department of Public Health and Environment

ec:

GABRIELE BENSON - pswdadmin@att.net; pswdorc@gmail.com;  
MICHAEL J WOLF - mwolf@wolfcompliance.org; customerservice@wolfcompliance.org;  
PINWOOD SPRINGS WD - pswdadmin@att.net; pswdorc@gmail.com;  
Keila Flores-Burgos - floresky@co.larimer.co.us; Larimer County Health Dept  
Nicole Rowan, Water Quality Control Division Director, CDPHE  
Ron Falco, WQCD SDW Program Manager  
Nathan Moore, WQCD CW Program Manager  
Tyson Ingels, WQCD ES Manager  
Heather Young, WQCD FSS Manager  
Nicole Graziano, WQCD DWCAS Manager  
Jorge Delgado, WQCD DWCAS Compliance North Unit Manager  
Robert Pohl, WQCD DWCAS Compliance South Unit Manager  
Stephanie Hosie, WQCD MHP Unit Manager  
MaryAnn Nason, WQCD Administrative Program Manager  
Kaitlyn Beekman, WQCD Communication Specialist  
Drinking Water Acute Response Team Leads, WQCD  
Sean Scott, DEHS, CDPHE  
Henry Mitchel. Office of Emergency Preparedness and Response, CDPHE  
Curt Drennen, Office of Emergency Preparedness and Response, CDPHE  
Korey Bell, Office of Emergency Preparedness and Response, CDPHE  
Angela Strand, Office of Emergency Preparedness and Response, CDPHE  
Pam Pergande, Office of Emergency Preparedness and Response, CDPHE  
Enteric Waterborne Disease Team, DCPHR, CDPHE Tessa Johnson - NORTH - A SW WQCD DWCAS  
Compliance Specialist

File: CO0135610, LARIMER, Community - Surface Water